

# PlanetSafe Test & Tag

Visit summary · generated 2026-06-19 · version v1

## Visit summary

Meridian Property Group · Parramatta office · visit 2026-06-19

|                       |                   |                           |                           |
|-----------------------|-------------------|---------------------------|---------------------------|
| ITEMS TESTED          | TEST RESULT: PASS | TEST RESULT: FAIL         | TEST RESULT: INCONCLUSIVE |
| 95                    | 91                | 3                         | 1                         |
| FAILED ITEMS RECORDED | TECHNICIAN        | MANUALLY RECORDED ENTRIES |                           |
| 3                     | R. Okafor         | 6                         |                           |

| ASSET    | ITEM                     | FAILURE REASON                                                               | STATUS |
|----------|--------------------------|------------------------------------------------------------------------------|--------|
| PS-2242V | Forklift battery charger | Insulation resistance below limit (0.62 M©, closed no retest limit e 1.0 M©) |        |
| PS-T8NMD | Paper shredder           | Insulation resistance below limit (0.62 M©, closed declined limit e 1.0 M©)  |        |
| PS-TDVD4 | Desk fan                 | Insulation resistance below limit (0.62 M©, action required limit e 1.0 M©)  |        |

Test results are the recorded outcome of each individual portable appliance test.