

PlanetSafe Test & Tag

Visit summary · generated 2025-08-21 · version v1

Visit summary

Meridian Property Group · Adelaide showroom & customer experience centre · visit 2025-08-21

ITEMS TESTED	TEST RESULT: PASS	TEST RESULT: FAIL	TEST RESULT: INCONCLUSIVE
30	29	1	0
FAILED ITEMS RECORDED	TECHNICIAN	MANUALLY RECORDED ENTRIES	
1	R. Okafor	6	

ASSET	ITEM	FAILURE REASON	STATUS
PS-B28FZ	Dishwasher (under-bench)	Insulation resistance below limit (0.62 M©, limit e 1.0 M©)	awaiting retest

Test results are the recorded outcome of each individual portable appliance test.